



MAXIMUM TRENCH WIDTH AT TOP OF PIPE:  
I.D. PLUS 30" FOR PIPE 15" AND UNDER.  
(1.5X I.D.) PLUS 18" FOR PIPE 18" AND OVER.

**GENERAL NOTES:**

1. **COMPACTION:** THE TESTING REQUIREMENTS SHALL BE PER THE CITY OF TUMWATER DEVELOPMENT GUIDELINES AND PUBLIC WORKS STANDARDS.
2. ALL MATERIALS, WORKMANSHIP, AND INSTALLATION SHALL BE IN CONFORMANCE WITH THE WSDOT STANDARD SPECIFICATIONS FOR ROAD, BRIDGE AND MUNICIPAL CONSTRUCTION OR AS AMENDED BY CITY OF TUMWATER STANDARDS.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
<b>WATER TRENCH DETAIL</b> <b>UNPAVED AREAS</b>				
APPROVED BY:				DWG. NO.
CITY ENGINEER				<b>WA-5.2</b>
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JUNE 2014	NOT TO SCALE