



HYDRANT BOLLARD
CROSS-SECTION A-A

GENERAL NOTES:

1. HYDRANT BOLLARDS SHALL BE INSTALLED 5' FROM THE HYDRANT SITUATED SO AS NOT TO BLOCK ANY OF THE HYDRANT PORTS.
2. THE HYDRANT BOLLARDS SHALL BE 6" IN DIAMETER SCHEDULE 20 STEEL POST AND FILLED WITH CONCRETE.
3. THE HYDRANT BOLLARDS SHALL BE COATED WITH 1 PRIME COAT AND TWO COATS OUTDOOR OIL BASE ENAMEL, "OSHA SAFETY YELLOW" COLOR, BY CONTRACTOR.
4. WHEN HYDRANT BOLLARDS ARE REQUIRED IN HIGH TRAFFIC AREAS, GLASS BEADS SHALL BE SPRAYED OR PLACED ON TO THE WET PAINT TO PROVIDE BETTER VISABILITY AT NIGHT.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
HYDRANT BOLLARDS				
APPROVED BY:				DWG. NO.
CITY ENGINEER				WA-14
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JUNE 2014	NOT TO SCALE