



**GENERAL NOTES:**

1. FOR VALVE BOX REQUIREMENTS SEE CITY DETAIL.
2. FILL THE AREA OUTSIDE OF THE BLOW-OFF RISER STAND PIPE WITH WASHED ROCK.
3. ALL 2" FITTINGS SHALL BE BRASS.
4. CARSON METER BOX SHALL HAVE A SOLID LID. A TRAFFIC RATED LID SHALL BE REQUIRED IF THE METER BOX IS IN THE TRAVELED WAY.
5. WHEN CONCEIVABLE LOCATE BLOW-OFF HYDRANT OUTSIDE ROADWAY.

**CITY OF TUMWATER, WASHINGTON**  
**DEPT. OF PUBLIC WORKS**  
  
**2" BLOW OFF ASSEMBLY FOR**  
**EXTENDABLE MAINS**

SET HYDRANT ON CONCRETE  
 BLOCK(S) AS REQUIRED

CARSON METER BOX  
 L-1730-15 WITH SOLID LID

PVC STAND PIPE

1 1/2"  
 WASHED  
 ROCK

APPROVED BY:

CITY ENGINEER

DWG. NO.

**WA-19**

DES. PW	DWG. BY PW	CKD BY KMC	DATE JULY 2014	NOT TO SCALE
---------	------------	------------	----------------	--------------