



VALVE BOX DETAIL

**GENERAL NOTES:**

1. THIS CONFIGURATION IS REQUIRED IF THE IRRIGATION SYSTEM DOES NOT HAVE IT'S OWN SEPARATE WATER METER.
2. DO NOT INSTALL IN AREAS SUBJECT TO FLOODING.
3. IF REDUCED PRESSURE DEVICE IS USED, BOX MUST BE FREE DRAINING.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
<b>IRRIGATION FOR RESIDENTIAL DOMESTIC SERVICE</b>				
APPROVED BY:				DWG. NO.
CITY ENGINEER				<b>WA-24</b>
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JULY 2014	NOT TO SCALE