



**GENERAL NOTES:**

1. ALL PIPE EASEMENTS SHALL BE A MINIMUM 15 FEET WIDE WITH THE PIPE CENTERED IN THE EASEMENT.
2. WHEN THE DCVA IS IN A VAULT OUTSIDE THE BUILDING, THE CITY EASEMENT SHALL ENCOMPASS THE VAULT 7.5 FEET OUTSIDE THE PERIMETER OF THE VAULT.
3. WHEN THE DCVA IS LOCATED WITHIN THE BUILDING, THE CITY EASEMENT SHALL END AT THE CITY VALVE.
4. THE FDC SHALL BE LOCATED WITHIN 10' OF A CITY FIRE HYDRANT.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
<b>FIRE SPRINKLER UNDERGROUND EASEMENT LIMITS</b>				
APPROVED BY:				DWG. NO.
CITY ENGINEER				<b>WA-41</b>
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JULY 2014	NOT TO SCALE