



GENERAL NOTES:

1. THE GENERAL NOTES FOR A TYPE 1 MANHOLE, DRAWING NUMBER 7-1, SHALL APPLY.
2. MANHOLE SHALL BE MINIMUM 54" DIAMETER UNLESS OTHERWISE APPROVED BY THE PUBLIC WORKS DIRECTOR.
3. INSIDE DROP CONNECTIONS SHALL NOT BE USED WHEN CONNECTED TO A FORCE MAIN.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
INSIDE DROP CONNECTION - PVC				
APPROVED _____				DWG. NO.
CITY ENGINEER				SS-8
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JAN. 2012	NOT TO SCALE