



**GENERAL NOTES:**

1. RESTRAIN JOINTS AS REQUIRED BY THE ENGINEER.
2. MAINTAIN A MINIMUM OF 1' BETWEEN MANHOLE JOINTS AND TEE.
3. VERTICAL PIPING SHALL NOT BE IN CONFLICT WITH LADDER. LADDER SHALL NOT BE REMOVED.
4. INTRAFLOW PIPING SHALL BE PER MANUFACTURER'S INSTRUCTIONS.
5. CONNECTION TO AN EXISTING MANHOLE SHALL BE MADE BY CORE DRILLING THE MANHOLE AND SEALING THE HOLE AROUND THE PIPE WITH LINK SEAL.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
<b>G.V. LOW PROFILE INSIDE DROP CONNECTION</b>				
APPROVED _____				DWG. NO.
CITY ENGINEER				<b>SS-9</b>
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JAN. 2012	NOT TO SCALE