



GENERAL NOTES:

1. THE CONCRETE CYLINDER SHALL BE BONDED TO THE BASE TO PREVENT THE EFFLUENT FROM SEEPING INTO THE GROUND.
2. THE AIR RELEASE VALVE FOR THE SEWER SHALL BE AN AUTOMATIC AIR RELEASE VALVE BY ARI.
3. A RAIN GUARD SHALL BE REQUIRED ON THE MANHOLE LID.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
<h1 style="margin: 0;">AIR RELEASE VALVE</h1>				
APPROVED				DWG. NO.
CITY ENGINEER				SS-16
DES. PW	DWG. BY PW	CK'D BY MW	DATE NOV. 2014	NOT TO SCALE