



- GENERAL NOTES:
1. FOR VALVE BOX REQUIREMENT SEE DETAIL 7-9.
 2. THIS IS A FUTURE SEWER PRESSURE/FORCE MAIN EXTENSION DETAIL AND THE TEST REQUIREMENTS SHALL BE PER SECTION 7A.070 TESTING UNDER FORCE MAINS.
 3. SEE SECTION 7D.030 FORCE MAIN FOR PIPING REQUIREMENTS.
 4. IN UNUSUAL CIRCUMSTANCES THE PIPE WITH THE BELL END (MIN. LENGTH 17') MAY BE REDUCED TO A SHORTER LENGTH BUT NOT LESS THAN 10'. ALL OTHER CHANGES SHALL BE UNDER THE DIRECTION OF THE CITY ENGINEER.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
PRESSURE MAINS FUTURE EXTENSION				
APPROVED				DWG. NO.
CITY ENGINEER				SS-25
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JAN. 2012	NOT TO SCALE