



GENERAL NOTES:

1. ALL MOTOR LEADS SHALL BE CONTINUOUS TO THE CABINET.
2. COAT INSIDE OF STRUCTURE WITH A MIN. 1" THICK HIGH GRADE CALCIUM ALUMINATE KERNEOS SEWPER COAT OR APPROVED EQUAL.
3. ALL CONNECTIONS EXPOSED TO THE WEATHER SHALL BE HEAT SHRUNK.
4. CABINET DOORS SHALL FACE THE WET WELL.
5. INSTALL RUBBER GROMMETS AT THE CONDUIT PENETRATIONS TO THE RISER.
6. THE CONCRETE PAD FOR THE CABINET SHALL BE A MINIMUM OF 8' X 7' X 6". THERE SHALL BE 4' OF WORKING SPACE TO THE FRONT OF THE CABINET.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
COMMUNITY S.T.E.P. ELECTRICAL SYSTEM				
APPROVED				DWG. NO.
CITY ENGINEER				SS-27
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JAN. 2012	NOT TO SCALE