



GENERAL NOTES:

1. CONCRETE ANCHOR(S) WITH LIFT RINGS ARE REQUIRED TO PREVENT THE TANK FROM FLOATING. SEE MANUFACTURER'S INSTALLATION INSTRUCTIONS OR SPECIFIC CUT SHEET FOR THE SIZE AND WEIGHT OF THE ANCHOR.
2. PRIOR TO THE INSTALLATION OF THE E-ONE 2012 SYSTEM A PRE-CONSTRUCTION MEETING SHALL BE HELD WITH THE CITY OF TUMWATER INSPECTOR.
3. NO SPLICES SHALL BE ALLOWED IN THE POWER CABLE BETWEEN THE CONTROL PANEL AND THE GRINDER UNIT.
4. CARE SHALL BE TAKEN TO PREVENT ANY DIRT, SAND OR DEBRIS FROM ENTERING THE GRINDER UNIT. THE INSIDE SHALL BE "FACTORY CLEAN" UPON FINAL INSPECTION AND PRIOR TO RUNNING THE PUMP.
5. THE INSTALLATION SHALL BE PER THE MANUFACTURER'S REQUIREMENTS OR THE WARRANTY MAY BE VOIDED.

SEMI-POSITIVE DISPLACEMENT TYPE PUMP DIRECTLY DRIVEN BY A 1 HP MOTOR CAPABLE OF DELIVERING 9 GPM AT 138' T.D.H.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
E-ONE 2012 COMMERCIAL SIZED PER MANUFACTURER'S REQUIREMENT				
APPROVED				DWG. NO.
CITY ENGINEER				SS-38
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JAN. 2012	NOT TO SCALE