



**GENERAL NOTES:**

1. CONCRETE PADS FOR ALL CURB INLET BASINS SHALL BE A MINIMUM OF 3' X 3' X 8.
2. ALL STORM MANHOLE LID AND RING ASSEMBLIES SHALL BE EAST JORDAN IRON WORKS OR OLYMPIC FOUNDRY.
3. ALL STORM MANHOLE LID AND RING ASSEMBLIES SHALL BE DUCTILE IRON AND MANUFACTURED IN THE USA.
4. THIS APPLICATION SHALL BE USED FOR INSTALLATIONS ON ARTERIALS AND BOULEVARDS OR WHEN STORM PIPING IS TOO SHALLOW TO MEET THE MINIMUM 2' OF COVER WHERE THE STORM PIPE ENDS UP IN THE ROADWAY STRUCTURE REGARDLESS OF THE TYPE OF PIPE BEING USED.
5. USE A 2" RECTANGULAR ADJUSTMENT SECTION TURNED LENGTHWISE TO ELIMINATE THE GAP UNDER THE FRAME.

CITY OF TUMWATER, WASHINGTON DEPT. OF PUBLIC WORKS				
<b>CURB INLET GRATE &amp; CATCH BASIN INSTALLATION</b>				
APPROVED				DWG. NO.
CITY ENGINEER				<b>SD-3</b>
DES. PW	DWG. BY PW	CK'D BY KMC	DATE JAN. 2012	NOT TO SCALE