



**SECTION A-A**

SEE NOTE 5

4" COMMERCIAL GRADE CONCRETE

**GENERAL NOTES:**

1. CURB INLET SHALL BE CONSTRUCTED IN ACCORDANCE WITH ASTM C 478 (AASHTO M 199) & ASTM C 890.
2. THE TOP SURFACE SHALL BE BROOM FINISHED.
3. ALL EXTERNAL EDGES NOT LABELED SHALL BE TROWELLED WITH 1/4" RADIUS EDGER.
4. INLETS SHOULD BE SPACED CONSISTENT WITH CATCH BASIN SPACING REQUIRED IN THE STORM WATER MANUAL.
5. WHERE CURB INLETS ARE USED, APPROXIMATELY 6 INCHES OF ROCK OR OTHER EROSION PROTECTION MATERIAL SHALL BE USED TO DISSIPATE ENERGY AND/OR FLOW DOWN THE CHUTE.
6. PERVIOUS PAVING MAY BE USED FOR INLET WITH CITY APPROVAL.
7. THE SLOPE OF THE CHUTE SHALL BE DETERMINED WHEN THE SWALE IS DESIGNED.

**SECTION B-B**

CITY OF TUMWATER, WASHINGTON  
DEPT. OF PUBLIC WORKS

**LID CURB INLET  
TYPE 1**

APPROVED

DWG. NO.

CITY ENGINEER

**SD-8**

DES.  
PW

DWG. BY  
PW

CK'D BY  
KMC

DATE  
JAN. 2012

NOT TO  
SCALE